



Opdrachtgever Testcentrum Meetdatum	Flex&CO B.V. merford noise control woensdag 27 november 2013	
Productomschrijving Aantal Afmetingen Signaal Volume ontvangruimte	vrijstaande of hangende akoestische panelen 6 st. 6 m ² roze ruis (pink noise) 220,8 m ³	

Frequentie [Hz]	Eq. Ab. TER [m ²]	
	Eq. Ab. TER [m ²]	Eq. Ab. OCT [m ²]
50	0,11	
63	0,19	0,19
80	0,26	
100	0,29	
125	0,40	0,38
160	0,47	
200	0,57	
250	0,78	0,7
315	0,74	
400	0,85	
500	0,96	0,95
630	1,03	
800	1,09	
1000	1,11	1,14
1250	1,20	
1600	1,24	
2000	1,32	1,28
2500	1,28	
3150	1,38	
4000	1,44	1,41
5000	1,41	
6300	1,43	
8000	1,30	1,33
10000	1,24	



spraak

